

RFP 24-01

Addendum 1

1. Do the fence post have to be sunk in cement or can they be driven into the ground?

All terminal post must be in concrete. The rest can be driven into the ground.

2. Do you want to use wood posts (same as you have now) for the type A fence.

Wood Post are preferred.

3. Can we mulch the brush that needs to be cleared and leave on site?

No

4. How long is the craftsmanship warranty for?

Contractor is to provide a guarantee of the quality of work or craftsmanship for 1 year after installation.

5. Are we replacing the fence in the exact location?

The new fence will be installed in the same footprint as the old fence.

6. There is a large portion of the fence where the adjacent property owner's have used the fence as a retaining wall. Are we responsible for the damage the fence could do to their yard? Have they been notified?

The fence is 1ft inside the drainage easement line. Contractor is responsible for restoring disturbed areas where possible.

Homeowners were notified and a town hall meeting was held to inform the residents of fence replacement.

7. Is there any grading required for the fence line?

Grading: Where necessary to secure proper vertical alignment and to provide a substantial and permanent foundation for the fence.

8. When are Addendum Questions due?

All Questions for the final Addendum (Addendum 2) must be submitted no later than Friday March 1st.